



NOTES:

- (A) LOCATION, GRADE, AND WIDTH TO BE ESTABLISHED OR APPROVED BY THE OWNER.
- (B) BASE TO BE COMPACTED TO EXCEED 95% OF STANDARD DENSITY.
- (C) SLOPE SIDEWALK TOWARD THE STREET NO LESS THAN 0.50% AND NOT TO EXCEED 2.00%.
- (D) SCORE AT INTERVALS TO MATCH WIDTH OF WALK NOT TO EXCEED 5 FEET SPACING.
- (E) 1/2" TRANSVERSE PREFORMED BITUMINOUS JOINTS AT THE TERMINUS POINTS FOR CURVE AND WHERE SIDEWALK IS PLACED BETWEEN TWO PERMANENT FOUNDATIONS, PLACE 1/2" EXPANSION JOINT MATERIAL ALONG THE BACK OF WALK THE FULL LENGTH. (TRANSVERSE EXPANSION JOINTS SHALL BE PLACED AT NO MORE THAN 20').
- (F) DRIVEWAY APPROACH ACROSS PLANTER STRIP TO BE 5" MINIMUM CONCRETE OVER 4" OF 3/4" MINUS CRUSHED BASE.
- (G) SIDEWALK WIDTH TO BE 5' MINIMUM UNLESS APPROVED BY THE CITY ENGINEER.
- (H) ON SIDEWALKS IN COMMERCIAL AREAS WHERE THE WALK EXTENDS FROM THE BUILDING TO THE CURBING, OR EXCEEDS THE STANDARD FIVE (5) FEET WIDTH, THE WALK SHALL BE LAID OUT IN BLOCKS NOT TO EXCEED TEN (10) FEET BY TEN (10) FEET SQUARES.
- (I) WHEN TRANSITIONING NEW SIDEWALK TO EXISTING SIDEWALK A 5 FOOT TRANSITION PANEL MAY BE CONSTRUCTED AND SHALL BE SEPARATED AND ISOLATED WITH EXPANSION MATERIAL.

2016

CITY  
OF  
TWIN FALLS

CONCRETE  
SIDEWALK

STANDARD DRAWING  
NO. **TFSD-709**