

Flushing of underground sprinkler pipes.

Due to recent events I am changing the process of how fire sprinkler underground pipes are flushed. From this point forward the following will be required when flushing a system in Twin Falls.

1. At no time will any person or persons be allowed to hold the pipe, hose, or any other device used for flushing the underground fire sprinkler piping.
2. Any device used for flushing the underground fire sprinkler system shall be secured in such a manner that does not allow the device to move.
3. Any pipe, hose, or any other device used for flushing, shall extend to a safe location outside of a building. Water will not be allowed to flow in a manner that could cause water to do build up around the structure, cause damage to the structure, or in other areas deemed to be hazardous.

If at any time I am asked to witness the flushing of a system and the above measures were not taken, or if it is deemed to be unsafe, the test shall be rescheduled for a different date.