



## City of Twin Falls Building Department

203 Main Ave. E.  
Twin Falls, ID 83301  
Phone: (208)735-7238  
Email: [buildingfax@tfid.org](mailto:buildingfax@tfid.org)  
Web: [www.tfid.org](http://www.tfid.org)

## Commercial Kitchen Hoods (Types 1 & 2)



### *Design Guide:*

## 2018 International Building and Mechanical Code and Commentaries

This is a **design review checklist** for code requirements for commercial kitchen hoods including grease ducts and their connections to hood and roof exhaust fans, exhaust fan details, make-up air details and suppression systems, etc. Please ensure the following items are fully addressed in the design documents. Also note that this list is a minimum scope of what we will be reviewing. Additional issues may arise as these items are addressed.

### Type 1 Hoods (IMC 507.2)

IMC SECTION 507.2 requires Type 1 hoods “where cooking appliances produce grease or smoke as a result of the cooking process”.

- 1) Show / note all cooking equipment that must be provided with a Type 1 hood.
- 2) UL listing for the Type 1 kitchen grease hoods to be installed. See IMC 507.1.
- 3) Provide a heat sensor or other device to insure the automatic operation of both the kitchen hood and the make-up air systems upon activation of the cooking devices. IMC 508.1.
- 4) Use Applications:  
Extra Heavy Duty (IMC 507.2.2): Type 1 hoods over these appliances shall not cover other appliances that require fire extinguishing equipment and such hoods shall discharge to an independent exhaust system.

- Fuel-burning Appliances (IMC 507.2.2): Provisions shall be made to prevent the hood system from interfering with the normal operation of the vents for these appliances.
- 5) Materials (IMC 507.2.3): Type 1 hoods shall be constructed of steel that is a minimum .0466 inch thick or stainless steel that is minimum .0335 inch thick.
  - 6) Supports shall be noncombustible and capable of supporting the hood, adjacent ductwork, the effluent load and the possible weight of the personnel working in or on the hood. IMC 507.2.4 (**Engineering for roof loads required**)
  - 7) Joints, seams, penetrations (IMC 507.2.5): External hood joints shall be made with a continuous liquid-tight weld or braze to the lower outermost perimeter of the hood. Internal joint, seams, penetrations, filter support frames, and other appendages shall not be required to be brazed or welded. They shall be sealed grease tight.
  - 8) Cleaning, grease gutters (IMC 507.2.9): The hood shall be designed to allow thorough cleaning of the entire hood. Grease gutters shall drain to an approved collection receptacle that is also easily cleaned.
  - 9) Clearances (IMC 507.2.6): Provide a minimum 18 inch clearance from the Type 1 grease hood to any combustible material. Clearance is not required for gypsum board attached to noncombustible structures provided that a smooth, cleanable, nonabsorbent and noncombustible material is applied between the gyp board and the hood. This material shall extend 18” minimum beyond all sides or edges of the hood.
  - 10) Show the location of the Type 1 hood in relation to the kitchen ceiling and walls. If any portion of the hood penetrates the ceiling,

wall or furred space it shall be enclosed from the point of penetration to the outlet terminal. IMC 506.3.11.

- 11) Provide performance, capture, & containment test for the Type hood system. The permit holder shall provide the necessary test equipment and devices required to test the equipment. IMC 507.6.

## 12) Fire Marshall Plan Review required.

### GREASE DUCT (IMC 506.3)

- 1) Provide the grease duct size. Note the design air velocity.
- 2) Provide the type of the joint seams and connections to be used for the installation of the grease duct to the Type 1 hood and exhaust fan.
- 3) Show the grease duct exhaust fan to be a minimum 10' above grade. Verify that the location will not be a public nuisance or create problems in general due to the location, direction, or nature of the exhaust.
- 4) Show the exhaust fan termination to be a minimum 40" above the roof. Show how one side is hinged with a flexible electrical connector for inspection and cleaning
- 5) Provide a "light test" for grease duct prior to enclosing or concealing. IMC 506.3.2.5.
- 6) Provide specifications, installation details and current ICC Evaluation Report for the grease duct wrap system. This wrap shall extend from 18 inches below any combustible truss or wood joist to a point 18" above the surface of the roof covering or provide an 18" clearance to combustible material for the same distance or provide a noncombustible 1-hr fire-rated shaft with a gyp board and 3" minimum clearance.

- 7) Address duct grease accumulation and cleanout per IMC 506.3.6.7-10
- 8) Address the grease duct enclosures per IMC 506.3.11 (including exceptions).

### MAKE-UP AIR (IMC 508):

- 1) Provide exhaust and makeup air calculations for the kitchen or the entire space as applicable. Include all sources of exhaust air and make-up air.
- 2) Provide an interlock device between all grease hoods and make-up air units to insure simultaneous operation when active.
- 3) Provide a heat sensor or other device to insure the automatic operation of both the kitchen hood and the make-up air systems upon activation of the cooking devices.
- 4) Makeup air intake opening locations shall comply with IMC 401.4
- 5) Makeup air temperature shall not vary from the conditioned space by more than 10°F.
- 6) Compensating hoods shall bear labels stating their air volume requirements.
- 7) A balance report, prepared by a qualified third party, shall be presented to Building dept.

### SUPPRESSION SYSTEM (IMC SECTION 509, IBC 904.2.2):

- 1) Provide plans and details for Type 1 hood approved automatic fire suppression system complying with the IBC and IFC. Include shutdown devices.
- 2) 2 A balance report, prepared by a qualified third party, shall be presented to COTF Building Dept.

## Type 2 Hoods (IMC 507.3)

"Type II hoods shall be installed above dishwashers and appliances that produce heat or moisture and do not produce grease or smoke as a result of the cooking process, except where the heat and moisture loads from such appliances are incorporated into the HVAC system design or into the design of a separate removal system. Type II hoods shall be installed above all appliances that produce products of *combustion* and do not produce grease or smoke as a result of the cooking process (ie., steamers, kettles, pasta cookers, and dishwashing machines). ***Spaces containing cooking appliances that do not require Type II hoods shall be provided with exhaust at a rate of 0.70 cfm per square foot...each individual appliance...shall be considered as occupying not less than 100 square feet.***"

- 1) Materials should be steel not less than .0296 (22 gauge), stainless steel not less than (24 gauge), or copper weighing 0.0220 not less than 24 oz. per sq. ft., or other *approved* material and gage.
- 2) Supports shall be noncombustible and capable of supporting the hood, adjacent ductwork, the effluent load and the possible weight of the personnel working in or on the hood. IMC 507.3.2. **(Engineering for roof loads required).**
- 3) Joints, seams, and penetrations shall be constructed as set forth in IMC Ch. 6, shall be sealed on the interior of the hood and provide a smooth surface that is readily cleanable and water tight. IMC 507.7.3.3.